United Arab Emirates
Ministry of interior
Civil Defense G.H.Q
Fire intentional Lab & House
Of Expertise & Training Center
Approval Committee



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

Date: 12 July 2022

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following				
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	296356 Issue 2 P110112-1001 P119347-1002 & 1006	CERTIFICATE NUMBER	568c/02 issue 14	
DATE OF ISSUE	16/02/2016 16/01/2018 10/03/2022	DATE OF ISSUE	05 April 2022	
DATE OF EXPIRY	N/A	DATE OF EXPIRY	N/A	
	Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	RAMCRO S.p.A.	NAME OF THE BRAND	RAMFIRECRO-F3	
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Via Marzorati, 15 20014 Nerviano Milan, Italy	MODEL / NO	RAMFIRECRO-F3 STANDARD FIRE SUN	
WEBSITE	www.ramcro.it	LOGO ON THE PRODUCT	ramero special 1 cables	
TEL	+39 0331 406 511	EMAIL	ramcro@ramcro.it	

BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

Product Details From Test Report			
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	The 'Ramfirecro-F3 Standard' cables comprise of a LTS 3 type zero halogen thermoplastic compound sheath encasing an outer polyester tape, bare tinned copper drain wire, aluminium polyester tape, inner polyester tape, plain annealed copper conductors insulated with EI2 type silicone rubber insulation. Ramfirecro-F3 Standard comply with the following standards: BS7629-1:2015 (Standard 60) BS6387:2013 CWZ a) Protocol BS6387 cat. C resistance to fire alone - 950°C for 3 hours (3hours fire resistance) b) Protocol BS6387 cat. W resistance to fire with water – Exposed to fire 650°C for 15min then exposed fire @ 650°C with water for another 15 mins. c) Protocol BS6387 cat. Z- Resistance to fire with mechanical shock. Exposed to fire @ 950°C for 15 mins. BS EN 50200 Min cat. PH120 Resistance to fire with mechanical shock. Exposed to fire @840°C for minimum 120 mins (PH120) BS EN 50200:2006 Annex E Resistance to fire with water – Exposed to fire and mechanical shock@840°C for 15 mins then exposed to fire, mechanical shock @840°C with water for another 15 mins.		
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	BS 7629-1:2015 (Standard 60) BS 6387: 2013 (Category CWZ) EN 50200:2015 (class PH120) EN 50200:2015 Annex E (30 mins) BS 5839-1:2013 (clause 26.2d standard) EN 60754-2:2014		
TEST DESCRIPTION	BS 7629-1:2015 Electric cables. Specification for 300/500 V fire resistant, screened, fixed installation cables having low emission of smoke and corrosive gases when affected by fire. Multicore cables EN 50200:2015 (PH120) Method of test for resistance to fire of unprotected small cables for use in emergency circuits		

United Arab Emirates Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee**



دولة الامارات العربية المتحدة وزارة الداخلية رر روبة القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

	EN 50200:2015 (Annex E) The duration of survival, measured in minutes, to the point of failure shall be recorded for each cable tested up to a maximum survival time of 30 min, with the water spray being applied for the last 15 min of the test. BS 6387:2013 - Test method for resistance to fire of cables required to maintain circuit integrity under fire conditions. BS 5839-1:2013 - Fire detection and fire alarm systems for buildings. Code of practice for system design, installation, commissioning and maintenance.	
SPECIFICATION OF TEST SPECIMEN	296356 issue 2 Samples tested to assess full range 2x1.0 mm² solid & stranded conductors, 3x2.5 mm² stranded conductor 4x4.0 mm² stranded conductor P110112-1001 Samples tested to assess full range 2x1.0 mm² solid & stranded conductors, 3x2.5 mm² stranded conductor 4x4.0 mm² stranded conductor P119347-1002 & 1006 Samples tested to assess full range 4x4.0 mm² stranded conductor	
TEST RESULT (SUCH AS PASSED CRITERIA/ COMPLIED TO/ DURATION/OBSERVATION/ETC)	Passed. All Samples complied with the requirements of the LPCB approved program. "This document is to be used in conjunction with certificate 568c/02"	
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN/TO BE INSTALLED AT/TO BE CONNECTED WITH/TO BE INSTALLED WITH ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN/NOT TO BE INSTALLED AT/ NOT TO BE INSTALLED WITHETC.	These special multicore cables are used for fire resistant and circuit integrity, and essentially to prevent life from smoke and noxious fumes, and where sensitive equipment may be damaged by acid forming gases. BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.	N.A.



دولة الامارات العربية المتحدة وزارة الداخلية رر روبة القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	BRE Global Ltd.	NAME OF TEST FACILITY	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	TEST FACILITY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	https://www.bregroup.com/about- us/bre-global/	WEBSITE	https://www.bregroup.com/about- us/bre-global/
TEL	+44 (0)333 321 88 11	TEL	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bregroup.com	EMAIL	BREGlobalEnquiries@bregroup.com
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	UKAS www.ukas.com	ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	UKAS www.ukas.com
AS PER (STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	EN45011: 1998 / ISO 17065: 2012	AS PER (STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)	ISO 17025: 2017
VALIDITY (EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)	N/A	VALIDITY (EXPIRY DATE OF LABORATORY ACCREDITATION)	N/A
REFERENCE NUMBER: (CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0007	REFERENCE NUMBER: (THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)	0578
CERTIFICATION MARK	LPCB BOOK CERTIFICATION OF CERTIFICATION		BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER				
NAME OF MANUFACTURER'S SIGNATORY	Luca De Gregoriis	SIGNATURE	En Defros S	
EMAIL / TEL	lucadegregoriis@ramcro.it	FACTORY OFFICIAL SEAL	RAMCRO S.p.A. Via Marzorati, 15 20014 NERVIANO (MI) Tel.0331.406.511 r.a. Fax 0331.406.529 - 0331.406.559 P.IVA 04698820158	
NOTES: I Undertake that all data and information provided are genuine and accurate				

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd.	SIGNATURE	B. Gohil 568c-02
EMAIL / TEL	BREGlobalEnquiries@bregroup.com +44 (0)333 321 88 11	CERTIFICATION BODY OFFICIAL SEAL	BRE GLOBAL LTD BUCKNALLS LANE WATFORD WD25 9XX U.K.
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)